


**DATE: March 17, 1988**

**TO:** BRIDGE DIVISION  
**FROM:** Veral Pinkerton, Bridge Engineer  
**SUBJECT:** Seals for Construction and Crack  
Control Joints - Using 1988  
Standard Specifications

On the plans, refer to 501.02 (h) for materials and to 501.04(j) for construction requirements.

If Type 3 or 4 joint sealer is used, detail the joint 3/8" wide by 1-1/2" deep with 1/2" backer  
rod 1/2" below surface.

Only one type of joint sealer shall be used on a jog.

My preference of sealer material is Type 6.  *1/4" x 1" (handwritten)*

VP:bw

FMH:bw

