Addendum No. 001

PROJECT NAME

ASUMH Multi-Use Trail Impvts. (TAP-22)(S)

PROJECT NUMBER

ARDOT Job #090677 F.A.P.: TAPSC-9299(14) (TAP-22)(S)

DATE

June 23, 2025

Issued By

Halff

SUBJECT

Addendum No. 001 to Bid Documents

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated 06-09-25. All bidders shall acknowledge receipt of this addendum in their bid submission. Failure to do so may result in disqualification of the bid.

Changes to Plans

1. Item 1: NONE

Changes to Specifications

1. Item 1: NONE

Clarifications

1. Item 1: Light pole base

- Question: Light pole base/footing detail on sheet C2.0 shows light pole mounted to concrete base and Fonroche pole detail shows an embedded depth of 4.5'
- Response: Light pole base shall be embedded 4.5' into the 6' deep concrete footing.

2. Item 2: Light pole base conduits

 Question: Light Pole Base/Footing shows conduits stubbed out for wired connection, however the light pole specified is solar. Response: Conduit shall not be installed in the light pole base. Conduit shall be eliminated from bid.

3. Item 3: Frisbee golf Course

- o Question: What are the circles on L1.0 that are connected with a line?
- Response: The circles, connected by lines on sheet L1.0 is a frisbee golf course shown for reference only.

Attachments

NONE

Direct questions to Jacob Shy, Director of Planning and Landscape Architecture, at jshy@halff.com – 479-466-1766